



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components

<i>Product Designation</i>	<i>Component Description</i>	<i>Nominal Rod Size, in. (mm)</i>	<i>Nominal Pipe Size, in.</i>
PKB10	Beam Clamp	3/8 (10)	3/4 through 4 *

*Approved for use with set screw on load side and set screw opposite load side.

Design

Jiangmen Eurofix Metal & Rubber Products Co Ltd
No 1 Tangbian Industrial Zone
Chaolian Town Jingmen City
Guangdong 529090
China

Manufacturing

Jiangmen Eurofix Metal & Rubber Products Co Ltd
No 1 Tangbian Industrial Zone
Chaolian Town Jingmen City
Guangdong 529090
China

FM Approvals Class: 1951, dated September 2003

Approval Identification: 0003055402

Approval Granted: June 17, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
AVP, Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components

<i>Product Designation</i>	<i>Component Description</i>	<i>Nominal Rod Size, in. (mm)</i>	<i>Nominal Pipe Size, in.</i>
PK12	Beam Clamp	1/2 (12)	5 through 8 **
PK16	Beam Clamp	5/8 (16)	10 through 12 **

** Approved for use with set screw on load side.

Design

Jiangmen Eurofix Metal & Rubber Products Co., Ltd.
No. 1 Tangbian Industrial Zone
Chaolian Town Jingmen City
Guangdong 529090
China

Manufacturing

Jiangmen Eurofix Metal & Rubber Products Co., Ltd.
No. 1 Tangbian Industrial Zone
Chaolian Town Jingmen City
Guangdong 529090
China

FM Approvals Class: 1951, dated September 2003

Approval Identification: 0003056695

Approval Granted: September 9, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
AVP - Manager, Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group